



Red River Authority of Texas

TODD W. BOYKIN, President, Amarillo
JERRY BOB DANIEL, Vice-President, Truscott
MICHAEL R. SANDEFUR, Secretary-Treasurer, Texarkana
STEPHEN A. THORNHILL, Assistant Secretary, Denison
MARY LOU BRADLEY, Memphis
JERRY DAN DAVIS, Wellington
GEORGE WILSON SCALING, II, Henrietta
ZACKARY K. SMITH, Canyon
JOE L. WARD, Telephone

RANDALL W. WHITEMAN, General Manager
FABIAN A. HEANEY, Assistant General Manager
DANNA P. BALES, Executive Assistant
LANA HEFTON, Controller

February 16, 2021
NOTICE OF DRINKING WATER
TOTAL TRIHALOMETHANES VIOLATION
RRA – Preston Shores Water System, ID No. 0910037

The Texas Commission on Environmental Quality (TCEQ) has notified the Authority's Preston Shores Water System that the drinking water supplied by the system has exceeded the Maximum Contaminant Level (MCL) for TOTAL TRIHALOMETHANES (TTHM's), as set in the Commissions Drinking Water Standards.

The MCL for TTHM's is 0.080 milligrams per liter (mg/L) and the MCL for HAA5's is 0.060 mg/L. Compliance with these levels is based on a running annual average of quarterly sample results. Preston Shores Water Systems running annual average for TTHM's in the fourth quarter of 2020 from DBP2-01 was 0.142 mg/L and DBP2-02 was 0.141 mg/L.

This is not an emergency. However, some people who drink water containing trihalomethanes or haloacetic acids in excess of the MCL over many years may experience problems with their liver, kidney, or central nervous systems, and may have an increased risk of getting cancer.

You do not need to use an alternative water supply. However, if you have health concerns, you may want to talk to your doctor to get more information about how this may affect you.

The Authority is working with engineers looking for an alternative solution to resolve these MCL violations. The Authority will continue to send letters out until the running annual average is below the required MCL.

Please share this information with all the other people who drink this water, especially those who may not have received this notice directly (for example, people in apartments, nursing homes, schools, and businesses). You can do this by posting this notice in a public place or distributing copies by hand or mail.

For further information, please contact Mr. Ron Mullins, Utility Supervisor, at the Red River Authority of Texas at (940) 723-8697. You may also contact your District Manager, Mr. Jason Whaley, at (903)786-9303.

Sincerely,

RED RIVER AUTHORITY OF TEXAS

A handwritten signature in cursive script that reads "Ronald A. Mullins".

Ron Mullins
Utility Regulatory Officer

RAM:slf